Certificate of constancy of performance

according to Regulation (EU) No. 305/2011

Certificate No.:	**1008-CPR-MC 69266706 0001**
Report No.:	**HU233QZ8 001**
Applicant:	REGITEC Solar BV Veldekensstraat 5A 8810 Lichtervelde Belgium
Manufacturer:	2086538
Manufacturing plant:	2086538
Product:	**Photovoltaic Cable (PV) family**
Identification:	H1Z2Z2-K 1X2,5…35 mm² (CPR-C_{ca}) Intended use: Cables for Communication Systems FPC Report No.: HU230KR8 001
System of assessment and verification:	1+
Tested according to:	EN 50575:2014+A1:2016

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.
This certificate was first issued on 2023-06-12 and it will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged. The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Certification Body

Date of issue:

Budapest, 2023-06-12

László Kocsis

TÜV Rheinland InterCert Kft., Product Certification Body — H-1143 Budapest, Gizella út 51-57. — www.tuv.com
Product certification body accredited by NAH under No NAH-6-0053/2018/K, Notified Body No. 1008

Validity of certificate can be checked on www.CERTIPEDIA.com

10/020 04.08. ® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.

Annex to certificate No. 1008-CPR-MC 69266706 0001

Azonosító / Identification	Védjegy / Trade Mark	Kereskedelmi név / Marketing név	Tűzvédelmi Osztály / Reaction to Fire classification
H1Z2Z2-K 1x2,5 mm^2 ($CPR\text{-}C_{ca}$)	REGITEC	REGITEC H1Z2Z2-K 1x2,5 mm^2 ($CPR\text{-}C_{ca}$)	C_{ca}-s1a,d1,a1
H1Z2Z2-K 1x4 mm^2 ($CPR\text{-}C_{ca}$)	REGITEC	REGITEC H1Z2Z2-K 1x4 mm^2 ($CPR\text{-}C_{ca}$)	C_{ca}-s1a,d1,a1
H1Z2Z2-K 1x6 mm^2 ($CPR\text{-}C_{ca}$)	REGITEC	REGITEC H1Z2Z2-K 1x6 mm^2 ($CPR\text{-}C_{ca}$)	C_{ca}-s1a,d1,a1
H1Z2Z2-K 1x10 mm^2 ($CPR\text{-}C_{ca}$)	REGITEC	REGITEC H1Z2Z2-K 1x10 mm^2 ($CPR\text{-}C_{ca}$)	C_{ca}-s1a,d1,a1
H1Z2Z2-K 1x16 mm^2 ($CPR\text{-}C_{ca}$)	REGITEC	REGITEC H1Z2Z2-K 1x16 mm^2 ($CPR\text{-}C_{ca}$)	C_{ca}-s1a,d1,a1
H1Z2Z2-K 1x25 mm^2 ($CPR\text{-}C_{ca}$)	REGITEC	REGITEC H1Z2Z2-K 1x25 mm^2 ($CPR\text{-}C_{ca}$)	C_{ca}-s1a,d1,a1
H1Z2Z2-K 1x35 mm^2 ($CPR\text{-}C_{ca}$)	REGITEC	REGITEC H1Z2Z2-K 1x35 mm^2 ($CPR\text{-}C_{ca}$)	$B2_{ca}$-s1a,d0,a1

Certification Body

Date of issue:

Budapest, 2023-06-12

László Kocsis

10/020 04.08. ® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.